

Project		Job Ref.			
MC Products					
Section			Sheet no./rev.		
M	asonry Wall Ou		1		
Calc. by	Date	Chk'd by	Date	App'd by	Date
R	11/1/2012				

Reinforced Masonry Wall Out-of-Plane Axial, Bending and Shear Forces;

Reference and notes: Reinforced Masonry Handbook use static equilibrium and strain compatibility. Enter forces per length of wall then use length of wall as center to center spacing of reinforcement. Reinforcement must be tied to be considered effective in carrying vertical load or compressive stress from bending. Because the reinforcement is not tied it will not be considered effective in for axial load. Wall is assumed to be partially grouted (grouted only at the location of the reinforcement).

Wall Geometry and Forces;

Height of wall; H=14.5ft; Center to Center spacing of reinforcement; b=48in;

Reinforcment size (bar number); $b_{num} = 4; \qquad A_s = pi/4*(b_{num}*1in/8)^2 = 0.196in^2;$

 $\begin{array}{lll} \mbox{Axial Load (per foot of wall);} & \mbox{P=0.9kip/ft;} \\ \mbox{Moment (per foot of wall);} & \mbox{M=0.42kip_ft/ft;} \\ \mbox{Shear;} & \mbox{V=0.116kip/ft;} \\ \end{array}$

Wall Properties (compare to Table GN-8b) Geometry;

(assumes face shells, cell at bar and webs each side of bar are grouted)

Nominal thickness of unit (height of x-section); h=7.625in; Depth to reinforcement; d=3.81in; Flange thickness; t_f =1.25in; Web thickness; t_w =1.0in;

Width of unit and width of grout; b_{unit}=15.625in; b_{grout}=0.375in;

Nominal width of unit; $b_{nunit} = b_{unit} + b_{grout} = 16.000 in;$ Width of web cell opening; $b_{cell} = (b_{unit} - 3^*t_w)/2 = 6.313 in;$ Width of web; $b_w = b_{cell} + 2^*t_w = 8.313 in;$ Height of web; $h_w = h - 2^*t_i = 5.125 in;$

Total area based on rebar spacing; $A=2*b*t_f+h_w*b_w=162.602in^2$;

Total moment of inertia based on rebar spacing; $l=b^*h^3/12-(b-b_w)/2^*h_w^3/12^*2=1328.090in^4$;

Radius of gryation; $r=(I/A)^{0.5}=2.858$ in;

Shear Area (disregard kd as max shear will not

occur at max moment); $A_v = b^*t_f + b_w^*(d - t_f) = 81.280 in^2$;

Wall Properties Material (See Tbl 2.2B or IBC 2105.2.2.1.2);

Allowable 1/3rd increase; i=1.33;

Maximum masonry compressive stress; f'_m '=1500psi; f'_m =f'_m'*i=1995.000psi;

Rebar yeild stress; $F_v=60$ ksi;

Modulus of Elasticity – steel; $E_s=29000ksi;$ $\epsilon_y=F_y/E_s=0.002in/in$ Modulus of Elasticity – masonry; $E_m=900*f_m=1795.500ksi;$ (use 700 for clay)

Modular ratio; $n=E_s/E_m=16.151$;

Allowable rebar stress; F_s '=max(F_v /2.5,24ksi); F_s = F_s '*i=**31920.000**psi;

Allowable compressive stress; $F_m=f'_m/3=665.000$ psi;

Slenderness Ratio; $\gamma = H/r = 60.883$

Reduction factor for slenderness; R1=1- $(\gamma/140)^2$ =**0.811**; R2= $(70/\gamma)^2$ =**1.322**;

R=if(γ <=99,R1,R2)=**0.811**;

Allowable axial stress; Fa= $0.25 \text{ f}'_{\text{m}} \text{R} = 404.426 \text{ psi};$



Project				Job Ref.	
	MC Products				
Section			Sheet no./rev.		
M	lasonry Wall Ou		2		
IV.	lacomy wan ca				_
Calc. by	Date Date	Chk'd by	Date	App'd by	Date

Allowable shear stress; Fv=min(1psi* $(f_m/1psi)^{0.5}$,50psi*i)=**44.665**psi;

Eccentricity required from loads; e_d=M/P=**5.600**in;

Analysis of Stesses;

Assume location of NA; kd=0.95 in;

Assume allowable compressive stress of

masonry controls; $f_m = F_m$;

 $\label{eq:continuous} Stress at flange/web intersection; & f_{cw}=f_m^*(kd-t'_f)/kd=\textbf{0.000}psi; \\ Stress in steel based on compatibility; & f'_s=n^*f_m/kd^*(d-kd)=\textbf{32.335}ksi; \\ Usable steel stress; & f_s=min(F_s,f'_s)=\textbf{31.920}ksi; \\ \end{cases}$

 $\begin{array}{ll} \text{Compressive force on flange;} & \text{C_{f}=0.5*(f_{m}$+$f_{cw}$)*t'_{f}$*b$=15.162$kip;} \\ \text{Compressive force on web;} & \text{C_{w}=0.5*y_{cw}*f_{cw}*b_{w}$=0.000$kip;} \\ \text{Tension force;} & \text{T=max(0kip,A_{s}*f_{s}$)$=6.267$kip;} \\ \end{array}$

Momemt Arm – Flange; $X_{cf}=h/2-t'_f*(2^*f_{cw}+f_m)/(3^*(f_{cw}+f_m))=3.496in;$

 $\label{eq:moment_strength} \begin{array}{ll} \text{Moment strength;} & \text{M}_{\text{cf}} = \text{X}_{\text{cf}} * \text{C}_{\text{f}} = \text{4.417kip_ft;} \\ \text{Moment Arm - Web;} & \text{X}_{\text{cw}} = \text{h/2-(t'}_{\text{f}} + \text{y}_{\text{cw}} / 3) = \text{2.863in;} \\ \text{Moment strength - Web;} & \text{M}_{\text{cw}} = \text{X}_{\text{cw}} * \text{C}_{\text{w}} = \text{0.000kip_ft;} \\ \text{Moment_{f}} & \text$

$$\label{eq:moment_strength} \begin{split} &\text{Moment Arm - Steel}; & X_{s1} = h/2 - d = \textbf{0.002} \text{in}; \\ &\text{Moment strength - steel}; & M_{s1} = X_{s1} * T = \textbf{0.001} \text{kip_ft}; \end{split}$$

Compressive force based on assumed kd

location and "fm=Fm"; $P_{ns}=C_f+C_w-T=8.895$ kip;

Moment stength of section based on assumed

kd location and "fm=FM"; $M_{ns} = M_{cf} + M_{cw} - M_{s1} = \textbf{4.416} \text{kip_ft};$

Eccentricity of section; $e_s=M_{ns}/P_{ns}=5.957$ in;

Compare to Eccentricity of Required; e_d=**5.600**in;

Checks;

Loads on effective wall length; $P_r=P^*b=3.600$ kip; $M_r=M^*b=1.680$ kip_ft; $V_r=V^*b=0.464$ kip;

Axial Stress; $f_a = P_r/A = \textbf{22.140} psi;$ Shear Stress; $f_v = V^*b/A_v = \textbf{5.709} psi$

 $\begin{array}{lll} \text{Check Axial Stress;} & \text{ChAx=if(f}_a<\text{Fa,"OK","NG")="OK";} \\ \text{Check Shear stress;} & \text{ChV=if(f}_v<\text{Fv,"OK","NG")="OK";} \\ \text{Check Axial Strength;} & \text{ChP=if(P}_{ns}>P_{r,"OK","NG")="OK";} \\ \text{Check Moment Strength;} & \text{ChM=if(M}_{ns}>M_{r,"OK","NG")="OK";} \\ \end{array}$

 $\begin{array}{ll} \mbox{Moment Utilization;} & \mbox{U_m=$M_r/$M}_{ns}$=$\textbf{0.380}; \\ \mbox{Axial Utilization;} & \mbox{U_a=$P_r/$P}_{ns}$=$\textbf{0.405}; \\ \end{array}$

Old max reinf. Ratio IBC 2006 (not found in 2009); $\rho_{max} = n^*f'_m/(2^*F_v^*(n+F_v/f'_m)) = 0.006$;